

linia SN 15 KV GPZ Wyszogród-Chylin - 0006/08
rodzaj uziemienia - taśmowo-prętowy

lp	numer słupa	wartość uziemienia do poprawy (Ω)	wartość uziemienia po poprawie (Ω)	uwagi
1	79/3			urwana bednarka
2	70/1			urwana bednarka
3	54/13/12			urwana bednarka
4	50/4			urwana bednarka
5	48/4	21,6		
6	40/1	18		
7	39/2			urwana bednarka
8	39	136,9		
9	28/6	15,11		
10	28/1	26,01		
11	165	17,6		
12	161/9	17,2		
13	135	62,1		
14	122/6	24,98		
15	122/30	180		
16	122/28	36,8		
17	122/24	152		
18	122/22	399		
19	122/2/8	21,08		
20	122/2/6	23,41		
21	122/2/5	21,4		
22	122/2/4	21,7		
23	122/2/39	109		
24	122/2/3	30,09		
25	122/2/2	16,54		
26	122/2/19	16,91		
27	122/2/18	44,9		
28	122/2/12	31,8		
29	122/2/10	15,83		
30	122/16	15,44		
31	122/1/3	18,7		
32	122/1/27	22,4		
33	122/1/21/4	18,9		
34	122/1/2	35,28		
35	122/1/16/8/2	16,8		
36	122/1/16/8/1	31,4		
37	114	15,81		
38	112	40,6		
39	111	26,97		
40	110	20,83		
41	109	21,59		
42	108	23,8		
43	107	18,56		